



Vista Labs

Analytical • Biological • Environmental

An ISO 9001:2015 &
OHSAS ISO 45001:2018 Certified Lab



Regn. No.20DQGN85

TEST REPORT

Page 1 of 1

Name & Address Of Customer: M/s. Sadhu Vaswani International School Kompally. C/o. Kishore.	Lab Ref. No:	VIS/2238/2023
	Reporting Date:	03/08/2023
	Sample Received On:	02/08/2023
	Your Ref No:	Verbal
	Analysis Started On:	02/08/2023
Sample Description: Main Block-R.O.water	Date of Sampling:	02/08/2023
Sample Condition At the time of Receipt: Found OK	Analysis Completed On:	03/08/2023
Sample drawn By: Customer	Quantity Received: 1Ltr X 1No.	

TEST RESULTS

Sl. No.	Characteristic Physical & Chemical	Test method	Results	Requirement (Acceptable Limit) As per IS 10500:2012
1.	P ^H Value at 25°C	IS:3025(Part -11)-1983,RA 2017	6.67	6.50 - 8.50
2.	Electrical conductivity @ 25°C, µS/cm	APHA (23 rd Edn:2017) -2510 B	204	Not specified
3.	Total Dissolved solids, mg/l	IS:3025(Part -16)-1984,RA 2006	136	< 500
4.	Turbidity, (NTU)	IS:3025(Part -10)-1984,RA 2017	< 1.0	< 1.0
5.	Colour, (Hazen Units)	IS:3025(Part -4)-1983,RA 2017	< 02	< 05
6.	Odour	IS:3025(Part -5)-1983,RA 2018	Agreeable	Agreeable
7.	Total Hardness as CaCO ₃ , mg/l	IS:3025(Part -21)-2009,RA 2014	56	< 200
8.	Alkalinity to Phenolphthalein as CaCO ₃ , mg/l	IS:3025(Part -23)-1986,RA 2014	Nil	Not specified
9.	Alkalinity to methyl orange as CaCO ₃ , mg/l	IS:3025(Part -23)-1986,RA 2014	40	< 200
10.	Calcium as Ca, mg/l	IS:3025(Part -40)1991,RA 2014	13.6	< 75
11.	Magnesium as Mg, mg/l	APHA (23 rd Edn:2017)-3500-Mg B	5.3	< 30
12.	Sodium as Na, mg/l	IS:3025(Part -45)-1993,RA 2014	21.2	Not specified
13.	Potassium as K, mg/l	IS:3025(Part -45)-1993,RA 2014	< 1.0	Not specified
14.	Chloride as Cl, mg/l	IS:3025(Part -32)-1988,RA 2014	44.0	< 250
15.	Sulphate as SO ₄ , mg/l	IS:3025(Part -24)-1986,RA 2014	< 5.0	< 200
16.	Nitrate as NO ₃ , mg/l	IS:3025(Part -34)-1988,RA 2014	< 0.1	< 45
17.	Fluoride as F, mg/l	APHA (23 rd Edn:2017)-4500-F D	0.50	< 1.0
18.	Total Silica as SiO ₂ , mg/l	APHA (23 rd Edn:2017)- 4500 SiO ₂ C	< 1.0	Not specified
19.	Iron as Fe, mg/l	APHA (23 rd Edn:2017)- 3500 Fe B	0.050	< 0.3

Note:

1. This report is valid for the tested sample(s) only.
2. Test report shall not be reproduced except in full & with written approval of VISTALABS.
3. This report should not be used for advertisement / judicial purpose.
4. Total Number Of Test(S) NINETEEN Only.
5. Lab will maintain unused portions of samples for 15 days after the report has been issued.

***** End of Report *****

[Signature]
Checked By

[Signature]
PRINCIPAL

Sadhu Vaswani International School
Kompally, Hyderabad.



VIS/LAB/F/047

4-9-6, Flat No. 103 & 104, Surya Towers, Adj. ANR Gardens, HMT Nagar, Nacharam, Hyderabad-500 076.
Ph : 040-27173815, 42210081, E-mail : vistalabs@yahoo.co.in, vistalabs2004@gmail.com



Vista Labs

Analytical • Biological • Environmental

An ISO 9001:2015 &
OHSAS ISO 45001:2018 Certified Lab



Regn. No.20DQGN85

TEST REPORT

Page 1 of 1

Name & Address Of Customer: M/s. Sadhu Vaswani International School Kompally. C/o. Kishore.	Lab Ref. No:	VIS/2237/2023
	Reporting Date:	03/08/2023
	Sample Received On:	02/08/2023
	Your Ref No:	Verbal
Sample Description: New Block-R.O.water	Analysis Started On:	02/08/2023
Sample Condition At the time of Receipt: Found OK	Date of Sampling:	02/08/2023
Sample drawn By: Customer	Quantity Received: 1Ltr X 1No.	Analysis Completed On: 03/08/2023

TEST RESULTS

Sl. No.	Characteristic Physical & Chemical	Test method	Results	Requirement (Acceptable Limit) As per IS 10500:2012
1.	P ^H Value at 25°C	IS:3025(Part -11)-1983,RA 2017	6.81	6.50 - 8.50
2.	Electrical conductivity @ 25°C, µS/cm	APHA (23 rd Edn:2017) -2510 B	112	Not specified
3.	Total Dissolved solids, mg/l	IS:3025(Part -16)-1984,RA 2006	72	< 500
4.	Turbidity, (NTU)	IS:3025(Part -10)-1984,RA 2017	< 1.0	< 1.0
5.	Colour, (Hazen Units)	IS:3025(Part -4)-1983,RA 2017	< 02	< 05
6.	Odour	IS:3025(Part -5)-1983,RA 2018	Agreeable	Agreeable
7.	Total Hardness as CaCO ₃ , mg/l	IS:3025(Part -21)-2009,RA 2014	16	< 200
8.	Alkalinity to Phenolphthalein as CaCO ₃ , mg/l	IS:3025(Part -23)-1986,RA 2014	Nil	Not specified
9.	Alkalinity to methyl orange as CaCO ₃ , mg/l	IS:3025(Part -23)-1986,RA 2014	35	< 200
10.	Calcium as Ca, mg/l	IS:3025(Part -40)1991,RA 2014	4.0	< 75
11.	Magnesium as Mg, mg/l	APHA (23 rd Edn:2017)-3500-Mg B	< 2.0	< 30
12.	Sodium as Na, mg/l	IS:3025(Part -45)-1993,RA 2014	18.4	Not specified
13.	Potassium as K, mg/l	IS:3025(Part -45)-1993,RA 2014	< 1.0	Not specified
14.	Chloride as Cl, mg/l	IS:3025(Part -32)-1988,RA 2014	14.9	< 250
15.	Sulphate as SO ₄ , mg/l	IS:3025(Part -24)-1986,RA 2014	< 5.0	< 200
16.	Nitrate as NO ₃ , mg/l	IS:3025(Part -34)-1988,RA 2014	< 0.1	< 45
17.	Fluoride as F, mg/l	APHA (23 rd Edn:2017)-4500-F D	0.50	< 1.0
18.	Total Silica as SiO ₂ , mg/l	APHA (23 rd Edn:2017)- 4500 SiO ₂ C	< 1.0	Not specified
19.	Iron as Fe, mg/l	APHA (23 rd Edn:2017)- 3500 Fe B	0.050	< 0.3

Note:

1. This report is valid for the tested sample(s) only.
2. Test report shall not be reproduced except in full & with written approval of VISTALABS.
3. This report should not be used for advertisement / judicial purpose.
4. Total Number Of Test(S) NINETEEN Only.
5. Lab will maintain unused portions of samples for 15 days after the report has been issued.

***** End of Report*****

 Checked By	 Authorised Signatory
---	---



G. Anjan
PRINCIPAL
Sadhu Vaswani International School
Kompally, Hyderabad.

VIS/LAB/F/047

4-9-6, Flat No. 103 & 104, Surya Towers, Adj. ANR Gardens, HMT Nagar, Nacharam, Hyderabad-500 076.
Ph : 040-27173815, 42210081, E-mail : vistalabs@yahoo.co.in, vistalabs2004@gmail.com

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. CL/W/9-8/8

Date: 8 Aug 2023

It is certified that an inspection team headed by E. KISHORE
lab manager (Name of Officers
with designation) from M/s. Vista Labs (Name of
Department/Office) inspected the Sadhu Vaswani (I) School
Sy. No: 150-152, Jayabheri Park, Kompally (Name & Address of
the School) on 08 Aug 2023 and found that the Sadhu Vaswani School
Kompally (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 07 March 2024

For VISTA LABS

Signature with Seal: E. KISHORE
Name: E. KISHORE
Designation: Lab Manager

To

Sadhu Vaswani (I) School.
Sy. No: 150-152, Jayabheri Park,
Kompally
(Name & Address of the Institution)

G. Arpita
PRINCIPAL
Sadhu Vaswani International School
Kompally, Hyderabad.