

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.

No. CL/W/07-07/12Date : 06 DEC 2024

It is certified that an inspection team headed by E. KISHORE  
Lab Manager (Name of Officers  
with designation) from M/s. Vista Labs. (Name of  
Department/Office) inspected the Sadhvi Vagwanii (I) School,  
Sy. No. 150-152 Jayabheri park, Kompally (Name & Address of  
the School) on 06 DEC 2024 and found that the Sadhvi Vagwanii School,  
Kompally. (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T Govt.

The above valid for a period of 05 June 2025

For VISTA LABS  
E. Kishore  
Signature with Seal : Proprietor  
Name : E. KISHORE  
Designation : Lab Manager

To

Sadhvi Vagwanii (I) School.  
Sy. No. 150-152 Jayabheri  
park, Kompally

(Name &amp; Address of the Institution)



# Vista Labs

Analytical • Biological • Environmental

An ISO 9001:2015 &  
OHSAS ISO 45001:2018 Certified Lab



Regn. No.23DQLD43

## TEST REPORT

Page 1 of 1

<b>Name &amp; Address Of Customer:</b> M/s. Sadhu Vaswani International School Kompally. C/o. Kishore.		<b>Lab Ref. No:</b>	<b>VIS/5140/2024</b>
		<b>Reporting Date:</b>	<b>18/12/2024</b>
		<b>Sample Received On:</b>	<b>17/12/2024</b>
		<b>Your Ref No:</b>	<b>Verbal</b>
<b>Sample Description: Old Block-R.O.water</b>		<b>Analysis Started On:</b>	<b>17/12/2024</b>
<b>Sample Condition At the time of Receipt: Found OK</b>		<b>Date of Sampling:</b>	<b>17/12/2024</b>
<b>Sample drawn By: Customer</b>	<b>Quantity Received: 1Ltr X 1No.</b>	<b>Analysis Completed On:</b>	<b>18/12/2024</b>

## TEST RESULTS



Sl. No.	Characteristic Physical & Chemical	Test method	Results	Requirement (Acceptable Limit) As per IS 10500:2012
1.	P <sup>H</sup> Value at 25°C	IS:3025(Part -11)-1983,RA 2017	6.73	6.50 - 8.50
2.	Electrical conductivity @ 25°C, µS/cm	APHA (23 <sup>rd</sup> Edn:2017) -2510 B	96	Not specified
3.	Total Dissolved solids, mg/l	IS:3025(Part -16)-1984,RA 2006	62	< 500
4.	Turbidity, (NTU)	IS:3025(Part -10)-1984,RA 2017	< 1.0	< 1.0
5.	Colour, (Hazen Units)	IS:3025(Part -4)-1983,RA 2017	< 02	< 05
6.	Odour	IS:3025(Part -5)-1983,RA 2018	Agreeable	Agreeable
7.	Total Hardness as CaCO <sub>3</sub> , mg/l	IS:3025(Part -21)-2009,RA 2014	15	< 200
8.	Alkalinity to Phenolphthalein as CaCO <sub>3</sub> , mg/l	IS:3025(Part -23)-1986,RA 2014	Nil	Not specified
9.	Alkalinity to methyl orange as CaCO <sub>3</sub> , mg/l	IS:3025(Part -23)-1986,RA 2014	30	< 200
10.	Calcium as Ca, mg/l	IS:3025(Part -40)-1991,RA 2014	3.6	< 75
11.	Magnesium as Mg, mg/l	APHA (23 <sup>rd</sup> Edn:2017)-3500-Mg B	< 2.0	< 30
12.	Sodium as Na, mg/l	IS:3025(Part -45)-1993,RA 2014	15.2	Not specified
13.	Potassium as K, mg/l	IS:3025(Part -45)-1993,RA 2014	< 1.0	Not specified
14.	Chloride as Cl, mg/l	IS:3025(Part -32)-1988,RA 2014	23.4	< 250
15.	Sulphate as SO <sub>4</sub> , mg/l	IS:3025(Part -24)-1986,RA 2014	< 5.0	< 200
16.	Nitrate as NO <sub>3</sub> , mg/l	IS:3025(Part -34)-1988,RA 2014	< 0.1	< 45
17.	Fluoride as F, mg/l	APHA (23 <sup>rd</sup> Edn:2017)-4500-F D	0.50	< 1.0
18.	Total Silica as SiO <sub>2</sub> , mg/l	APHA (23 <sup>rd</sup> Edn:2017)- 4500 SiO <sub>2</sub> C	< 1.0	Not specified
19.	Iron as Fe, mg/l	APHA (23 <sup>rd</sup> Edn:2017)- 3500 Fe B	0.050	< 0.3

### Note:

1. This report is valid for the tested sample(s) only.
2. Test report shall not be reproduced except in full & with written approval of VISTALABS.
3. This report should not be used for advertisement / judicial purpose.
4. Total Number Of Test(S) NINETEEN Only.
5. Lab will maintain unused portions of samples for 15 days after the report has been issued.

IS 10500: 2012 = Drinking water Specification

\*\*\*\*\* End of Report\*\*\*\*\*

 Checked By	 Authorized Signatory
---	---

VIS/LAB/F/047

# 4-9-6, Flat No. 103 & 104, Surya Towers, Adj. ANR Gardens, HMT Nagar, Nacharam, Hyderabad-500 076.  
Ph : 040-27173815, 42210081, E-mail : vistalabs@yahoo.co.in, vistalabs2004@gmail.com





# Vista Labs

Analytical • Biological • Environmental

An ISO 9001:2015 &  
OHSAS ISO 45001:2018 Certified Lab



Regn. No.23DQLD43

## TEST REPORT

Page 1 of 1

<b>Name &amp; Address Of Customer:</b> M/s. Sadhu Vaswani International School Kompally. C/o. Kishore.		<b>Lab Ref. No:</b>	<b>VIS/5139/2024</b>
		<b>Reporting Date:</b>	<b>18/12/2024</b>
		<b>Sample Received On:</b>	<b>17/12/2024</b>
		<b>Your Ref No:</b>	<b>Verbal</b>
<b>Sample Description: New Block-R.O.water</b>		<b>Analysis Started On:</b>	<b>17/12/2024</b>
<b>Sample Condition At the time of Receipt: Found OK</b>		<b>Date of Sampling:</b>	<b>17/12/2024</b>
<b>Sample drawn By: Customer</b>	<b>Quantity Received: 1Ltr X 1No.</b>	<b>Analysis Completed On:</b>	<b>18/12/2024</b>

## TEST RESULTS



Sl. No.	Characteristic Physical & Chemical	Test method	Results	Requirement (Acceptable Limit) As per IS 10500:2012
1.	P <sup>H</sup> Value at 25°C	IS:3025(Part -11)-1983,RA 2017	6.84	6.50 - 8.50
2.	Electrical conductivity @ 25°C, µS/cm	APHA (23 <sup>rd</sup> Edn:2017) -2510 B	108	Not specified
3.	Total Dissolved solids, mg/l	IS:3025(Part -16)-1984,RA 2006	70	< 500
4.	Turbidity, (NTU)	IS:3025(Part -10)-1984,RA 2017	< 1.0	< 1.0
5.	Colour, (Hazen Units)	IS:3025(Part -4)-1983,RA 2017	< 02	< 05
6.	Odour	IS:3025(Part -5)-1983,RA 2018	Agreeable	Agreeable
7.	Total Hardness as CaCO <sub>3</sub> , mg/l	IS:3025(Part -21)-2009,RA 2014	16	< 200
8.	Alkalinity to Phenolphthalein as CaCO <sub>3</sub> , mg/l	IS:3025(Part -23)-1986,RA 2014	Nil	Not specified
9.	Alkalinity to methyl orange as CaCO <sub>3</sub> , mg/l	IS:3025(Part -23)-1986,RA 2014	25	< 200
10.	Calcium as Ca, mg/l	IS:3025(Part -40)-1991,RA 2014	4.0	< 75
11.	Magnesium as Mg, mg/l	APHA (23 <sup>rd</sup> Edn:2017)-3500-Mg B	< 2.0	< 30
12.	Sodium as Na, mg/l	IS:3025(Part -45)-1993,RA 2014	17.5	Not specified
13.	Potassium as K, mg/l	IS:3025(Part -45)-1993,RA 2014	< 1.0	Not specified
14.	Chloride as Cl, mg/l	IS:3025(Part -32)-1988,RA 2014	20.6	< 250
15.	Sulphate as SO <sub>4</sub> , mg/l	IS:3025(Part -24)-1986,RA 2014	< 5.0	< 200
16.	Nitrate as NO <sub>3</sub> , mg/l	IS:3025(Part -34)-1988,RA 2014	< 0.1	< 45
17.	Fluoride as F, mg/l	APHA (23 <sup>rd</sup> Edn:2017)-4500-F D	0.50	< 1.0
18.	Total Silica as SiO <sub>2</sub> , mg/l	APHA (23 <sup>rd</sup> Edn:2017)- 4500 SiO <sub>2</sub> C	< 1.0	Not specified
19.	Iron as Fe, mg/l	APHA (23 <sup>rd</sup> Edn:2017)- 3500 Fe B	0.050	< 0.3

### Note:

1. This report is valid for the tested sample(s) only.
2. Test report shall not be reproduced except in full & with written approval of VISTALABS.
3. This report should not be used for advertisement / judicial purpose.
4. Total Number Of Test(S) NINETEEN Only.
5. Lab will maintain unused portions of samples for 15 days after the report has been issued.

IS 10500: 2012 = Drinking water Specification

\*\*\*\*\* End of Report\*\*\*\*\*

 <b>Checked By</b>	 <b>Authorized Signatory</b>
--	---

VIS/LAB/F/047

# 4-9-6, Flat No. 103 & 104, Surya Towers, Adj. ANR Gardens, HMT Nagar, Nacharam, Hyderabad-500 076.  
Ph : 040-27173815, 42210081, E-mail : vistalabs@yahoo.co.in, vistalabs2004@gmail.com