

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. CL/W/56-05/07.

Date : 05 July 2026

It is certified that an inspection team headed by E. KISHORE
Lab Manager (Name of Officers
with designation) from M/S. Vista Labs. (Name of
Department/Office) inspected the Sadhu Vaswani (I) School,
Sy No. 150-152, Jayabheri park, Kompally (Name & Address of
the School) on 05 July 2026 and found that the Sadhu Vaswani School,
Kompally. (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 04 Jan 2027

For VISTA LABS
Signature with Seal : E. KISHORE
Name : E. KISHORE **Proprietor**
Designation : Lab Manager

To
Sadhu Vaswani (I) School,
150-152 Jayabheri park
Kompally.
(Name & Address of the Institution)



Vista Labs

Analytical • Biological • Environmental

An ISO 9001:2015 &

OHSAS ISO 45001:2018 Certified Lab



Regn. No.23DQLD43

TEST REPORT

Page 1 of 1

Name & Address Of Customer:		Lab Ref. No:	VIS/2067/2026
M/s. Sadhu Vaswani International School		Reporting Date:	04/07/2026
Kompally.		Sample Received On:	03/07/2026
C/o. Kishore.		Your Ref No:	Verbal
Sample Description: Old Block-R.O. water		Analysis Started On:	03/07/2026
Sample Condition At the time of Receipt: Found OK		Date of Sampling:	03/07/2026
Sample drawn By: Customer	Quantity Received: 1Ltr X 1No.	Analysis Completed On:	04/07/2026

TEST RESULTS

Sl. No.	Characteristic Physical & Chemical	Test method	Results	Requirement (Acceptable Limit) As per IS 10500:2012
1.	P ^H Value at 25°C	IS:3025(Part -11)-1983, RA 2017	6.81	6.50 - 8.50
2.	Electrical conductivity @ 25°C, µS/cm	APHA (23 rd Edn:2017) -2510 B	90	Not specified
3.	Total Dissolved solids, mg/l	IS:3025(Part -16)-1984, RA 2006	58	< 500
4.	Turbidity, (NTU)	IS:3025(Part -10)-1984, RA 2017	< 1.0	< 1.0
5.	Colour, (Hazen Units)	IS:3025(Part -4)-1983, RA 2017	< 02	< 05
6.	Odour	IS:3025(Part -5)-1983, RA 2018	Agreeable	Agreeable
7.	Total Hardness as CaCO ₃ , mg/l	IS:3025(Part -21)-2009, RA 2014	14	< 200
8.	Alkalinity to Phenolphthalein as CaCO ₃ , mg/l	IS:3025(Part -23)-1986, RA 2014	Nil	Not specified
9.	Alkalinity to methyl orange as CaCO ₃ , mg/l	IS:3025(Part -23)-1986, RA 2014	26	< 200
10.	Calcium as Ca, mg/l	IS:3025(Part -40)1991, RA 2014	3.4	< 75
11.	Magnesium as Mg, mg/l	APHA (23 rd Edn:2017)-3500-Mg B	< 2.0	< 30
12.	Sodium as Na, mg/l	IS:3025(Part -45)-1993, RA 2014	14.3	Not specified
13.	Potassium as K, mg/l	IS:3025(Part -45)-1993, RA 2014	< 1.0	Not specified
14.	Chloride as Cl, mg/l	IS:3025(Part -32)-1988, RA 2014	13.5	< 250
15.	Sulphate as SO ₄ , mg/l	IS:3025(Part -24)-1986, RA 2014	< 5.0	< 200
16.	Nitrate as NO ₃ , mg/l	IS:3025(Part -34)-1988, RA 2014	< 0.1	< 45
17.	Fluoride as F, mg/l	APHA (23 rd Edn:2017)-4500-F D	0.50	< 1.0
18.	Total Silica as SiO ₂ , mg/l	APHA (23 rd Edn:2017)- 4500 SiO ₂ C	< 1.0	Not specified
19.	Iron as Fe, mg/l	APHA (23 rd Edn:2017)- 3500 Fe B	0.050	< 0.3

Note:

IS 10500: 2012 = Drinking water Specification

1. This report is valid for the tested sample(s) only.
2. Test report shall not be reproduced except in full & with written approval of VISTALABS.
3. This report should not be used for advertisement / judicial purpose.
4. Total Number Of Test(S) NINETEEN Only.
5. Lab will maintain unused portions of samples for 15 days after the report has been issued.

***** End of Report*****

	
Checked By	Authorized Signatory

VIS/LAB/F/047

4-9-6, Flat No. 103 & 104, Surya Towers, Adj. ANR Gardens, HMT Nagar, Nacharam, Hyderabad-500 076.
Ph : 040-27173815, 42210081, E-mail : vistalabs@yahoo.co.in, vistalabs2004@gmail.com



Vista Labs

Analytical • Biological • Environmental

An ISO 9001:2015 &

OHSAS ISO 45001:2018 Certified Lab



Regn. No.23DQLD43

TEST REPORT

Page 1 of 1

Name & Address Of Customer: M/s. Sadhu Vaswani International School Kompally. C/o. Kishore.		Lab Ref. No:	VIS/2068/2026
		Reporting Date:	04/07/2026
		Sample Received On:	03/07/2026
		Your Ref No:	Verbal
Sample Description: New Block-R.O. water		Analysis Started On:	03/07/2026
Sample Condition At the time of Receipt: Found OK		Date of Sampling:	03/07/2026
Sample drawn By: Customer	Quantity Received: 1Ltr X 1No.	Analysis Completed On:	04/07/2026

TEST RESULTS

Sl. No.	Characteristic Physical & Chemical	Test method	Results	Requirement (Acceptable Limit) As per IS 10500:2012
1.	P ^H Value at 25°C	IS:3025(Part -11)-1983, RA 2017	6.88	6.50 - 8.50
2.	Electrical conductivity @ 25°C, µS/cm	APHA (23 rd Edn:2017) -2510 B	104	Not specified
3.	Total Dissolved solids, mg/l	IS:3025(Part -16)-1984, RA 2006	68	< 500
4.	Turbidity, (NTU)	IS:3025(Part -10)-1984, RA 2017	< 1.0	< 1.0
5.	Colour, (Hazen Units)	IS:3025(Part - 4)-1983, RA 2017	< 02	< 05
6.	Odour	IS:3025(Part - 5)-1983, RA 2018	Agreeable	Agreeable
7.	Total Hardness as CaCO ₃ , mg/l	IS:3025(Part -21)-2009, RA 2014	16	< 200
8.	Alkalinity to Phenolphthalein as CaCO ₃ , mg/l	IS:3025(Part -23)-1986, RA 2014	Nil	Not specified
9.	Alkalinity to methyl orange as CaCO ₃ , mg/l	IS:3025(Part -23)-1986, RA 2014	30	< 200
10.	Calcium as Ca, mg/l	IS:3025(Part -40)-1991, RA 2014	4.0	< 75
11.	Magnesium as Mg, mg/l	APHA (23 rd Edn:2017)-3500-Mg B	< 2.0	< 30
12.	Sodium as Na, mg/l	IS:3025(Part -45)-1993, RA 2014	16.6	Not specified
13.	Potassium as K, mg/l	IS:3025(Part -45)-1993, RA 2014	< 1.0	Not specified
14.	Chloride as Cl, mg/l	IS:3025(Part -32)-1988, RA 2014	15.6	< 250
15.	Sulphate as SO ₄ , mg/l	IS:3025(Part -24)-1986, RA 2014	< 5.0	< 200
16.	Nitrate as NO ₃ , mg/l	IS:3025(Part -34)-1988, RA 2014	< 0.1	< 45
17.	Fluoride as F, mg/l	APHA (23 rd Edn:2017)-4500-F D	0.50	< 1.0
18.	Total Silica as SiO ₂ , mg/l	APHA (23 rd Edn:2017)- 4500 SiO ₂ C	< 1.0	Not specified
19.	Iron as Fe, mg/l	APHA (23 rd Edn:2017)- 3500 Fe B	0.050	< 0.3

Note:

1. This report is valid for the tested sample(s) only.
2. Test report shall not be reproduced except in full & with written approval of VISTALABS.
3. This report should not be used for advertisement / judicial purpose.
4. Total Number Of Test(S) NINETEEN Only.
5. Lab will maintain unused portions of samples for 15 days after the report has been issued.

IS 10500: 2012 = Drinking water Specification

***** End of Report *****

	
Checked By	Authorized Signatory

VIS/LAB/F/047

4-9-6, Flat No. 103 & 104, Surya Towers, Adj. ANR Gardens, HMT Nagar, Nacharam, Hyderabad-500 076.
Ph : 040-27173815, 42210081, E-mail : vistalabs@yahoo.co.in, vistalabs2004@gmail.com